

TECHNICAL SPECN.OF THE TENDER NO.MP/Q/003620/10-11 DT 13-08-2010

HOT FINISHED WELDED OR ERW OR INDUWELD STEEL PIPES GALVANISED PER IS 1239 (PART 1) /1980 MEDIUM QUALITY WITH SCREWED AT BOTH ENDS AND SOCKET AT ONE END. PIPES SHALL BEAR THE STAMPING /STENCILLING OF MANUFACTURERS MONOGRAM/ INSIGNIA, SIZE AND SPECIFICATION . ALL PIPES SHALL PROCURED WITH MANUFACTERERS TEST CERTIFICATE AND IT SHOULD CORELATE WITH THE SUPPLY. MTC REQUIRED.