

TECHNICAL SPECN.OF THE TENDER NO.MP/Q/003621/10-11 DT 13-08-2010

ERW OR INDUWELD STEEL PIPES GALVANISED PER IS 1239 (PART-1) /1980 HEAVY WITH WORKS TEST CERTIFICATE WITH SCREWED AT BOTHB ENDS AND SOCKET AT ONE END. ALL PIPES SHALL BEAR THE STAMPING/ STENCILLING OF MANUFACTURERS MONOGRAM / INSIGNIAS SIZE AND SPECIFICATION. PIPES SHALL PROCURE WITH MANUFACTURERS TEST CERTIFICATE. MTC SHOULD CO-RELATE WITH THE SUPPLY. MTC REQUIRED. PIPES SHALL BE RANDAM LENGTH OF SIX METER.